

## Water Audit Level 1 Validation – Review Document

### Audit Information:

Utility: Arcadia      PWS ID: 5810002  
 System Type: Potable      Audit Period: Calendar 2017  
 Utility Representation: Jacquelyn Mercado  
 Validation Date: 8/23/2018      Call Time: 8:30 am      Sufficient Supporting Documents Provided: Yes

### Validation Findings & Confirmation Statement:

#### Key Audit Metrics:

Data Validity Score: 71    Data Validity Band (Level): Band IV (71-90)  
 ILL: 2.61      Real Loss: 43.29 (gal/conn/day)      Apparent Loss: 74.59 (gal/conn/day)  
 Non-Revenue Water as a Percentage of Operating Costs: 7.0%

#### Certification Statement by Validator:

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

### Validator Information:

Water Audit Validator: Larry Lewison    Validator Qualifications: Contractor for California Water Loss TAP

Validator Provided